

Project Name

Location

Prepared By



# NUVO 62-1725-EM

9" SQ BLINK PRO EM BATT BACKUP

**Notes**

[www] 01-28-2025 00:30:18

**General**

|                 |                                   |
|-----------------|-----------------------------------|
| Status          | Active                            |
| Voltage         | 120V                              |
| Finish          | Black                             |
| Safety Listing  | cULus - Certified; cULus - Listed |
| Location Rating | Dry                               |
| Each UPC        | 045923561313                      |

**Physical**

|               |       |
|---------------|-------|
| Finish Family | Black |
|---------------|-------|

**Additional Information**

|                        |   |
|------------------------|---|
| Additional Information | 90 Minute Battery Runtime; 24 Hour Recharge Time; Fixture not included; Battery should be changed approximately every 2 years |
| Installation Notes     | Compatible with 3 in. and 4 in. J-Box & Pancake; 10.5ft Max Mounting Height   |
| For Use With           | 62-1725   |
| Warranty               | 5 Year Limited - Fixtures   |

**Compliance**

|                    |   |
|--------------------|---|
| California Prop 65 | Lead                                      |
| UL Application     | Low Frequency Emergency Lighting Inverter |
| RoHS Compliant     | Yes                                       |
| FCC Compliant      | Yes                                       |