

Project Name

Location

Prepared By



NUVO 62-1726-EM

9" SQ BLINK PRO EM BATT BACKUP

Notes

[www] 05-21-2025 00:07:13

General

Status	Active
Voltage	120V
Finish	Bronze
Safety Listing	cULus - Certified; cULus - Listed
Location Rating	Dry
Each UPC	045923561320

Physical

Finish Family	Bronze
Material	5VA Plastic

Additional Information

Additional Information	90 Minute Battery Runtime; 24 Hour Recharge Time; Fixture not included; Battery should be changed approximately every 2 years
Installation Notes	Compatible with 3 in. and 4 in. J-Box & Pancake; 10.5ft Max Mounting Height
For Use With	62-1726
Warranty	1-Year

Compliance

California Prop 65	Lead
UL Application	Low Frequency Emergency Lighting Inverter
RoHS Compliant	Yes
FCC Compliant	Yes
Canadian Standard ICES-005	Class A