

Project Name

Location

Prepared By



**NUVO 62-1727-EM**

9" SQ BLINK PRO EM BATT BACKUP

**General**

Status	Active
Voltage	120V
Finish	Brushed Nickel
Safety Listing	cULus - Certified; cULus - Listed
Location Rating	Dry
Each UPC	045923561337

**Physical**

Finish Family	Nickel
---------------	--------

**Additional Information**

Additional Information	90 Minute Battery Runtime; 24 Hour Recharge Time; Fixture not included; Battery should be changed approximately every 2 years
Installation Notes	Compatible with 3 in. and 4 in. J-Box & Pancake; 10.5ft Max Mounting Height
For Use With	62-1727
Warranty	5 Year Limited - Fixtures

**Compliance**

California Prop 65	Lead
UL Application	Low Frequency Emergency Lighting Inverter
RoHS Compliant	Yes
FCC Compliant	Yes

**Notes**

[www] 02-03-2023 00:48:44