SATCO NUVO

Project Name

Location Prepared By



Notes

| Status | Active |
|-----------------|-----------------------------------|
| Voltage | 120V |
| Finish | Black |
| Safety Listing | cULus - Certified; cULus - Listed |
| Location Rating | Dry |
| Each UPC | 045923561238 |

| | , | |
|------------------------|---|--|
| Each UPC | 045923561238 | |
| Physical | | |
| Finish Family | Black | |
| Material | Die-Cast Aluminum | |
| Additional Information | | |
| Additional Information | 90 Minute Battery Runtime; 24 Hour Recharge Time; Fixture not included; Battery should be changed approximately every 2 years | |
| Installation Notes | Compatible with 3 in. and 4 in. J-Box & Pancake | |
| For Use With | 62-1715 | |
| Warranty | 1-Year | |
| Compliance | | |
| California Prop 65 | Lead | |
| UL Application | Low Frequency Emergency Lighting Inverter | |
| | | |

Yes

Yes

Class A



RoHS Compliant

Canadian Standard ICES-005

FCC Compliant