

Project Name

Location

Prepared By



NUVO 62-1716-EM

7" SQ BLINK PRO EM BATT BACKUP

Notes

[www] 08-14-2025 23:35:41

General

| | |
|-----------------|-----------------------------------|
| Status | Active |
| Voltage | 120V |
| Finish | Bronze |
| Safety Listing | cULus - Certified; cULus - Listed |
| Location Rating | Dry |
| Each UPC | 045923561245 |

Physical

| | |
|---------------|-------------------|
| Finish Family | Bronze |
| Material | Die-Cast Aluminum |

Additional Information

| | |
|------------------------|---|
| Additional Information | 90 Minute Battery Runtime; 24 Hour Recharge Time; Fixture not included; Battery should be changed approximately every 2 years |
| Installation Notes | Compatible with 3 in. and 4 in. J-Box & Pancake |
| For Use With | 62-1716 |
| Warranty | 1-Year |

Compliance

| | |
|----------------------------|---|
| California Prop 65 | Lead |
| UL Application | Low Frequency Emergency Lighting Inverter |
| RoHS Compliant | Yes |
| FCC Compliant | Yes |
| Canadian Standard ICES-005 | Class A |