

Project Name

Location

Prepared By



**NUVO 62-1717-EM**

7" SQ BLINK PRO EM BATT BACKUP

**General**

|                 |                                   |
|-----------------|-----------------------------------|
| Status          | Active                            |
| Voltage         | 120V                              |
| Finish          | Brushed Nickel                    |
| Safety Listing  | cULus - Certified; cULus - Listed |
| Location Rating | Dry                               |
| Each UPC        | 045923561252                      |

**Physical**

|               |                   |
|---------------|-------------------|
| Finish Family | Nickel            |
| Material      | Die-Cast Aluminum |

**Additional Information**

|                        |   |
|------------------------|---|
| Additional Information | 90 Minute Battery Runtime; 24 Hour Recharge Time; Fixture not included; Battery should be changed approximately every 2 years |
| Installation Notes     | Compatible with 3 in. and 4 in. J-Box & Pancake   |
| For Use With           | 62-1717   |
| Warranty               | 5 Year Limited - Fixtures   |

**Compliance**

|                    |   |
|--------------------|---|
| California Prop 65 | Lead                                      |
| UL Application     | Low Frequency Emergency Lighting Inverter |
| RoHS Compliant     | Yes                                       |
| FCC Compliant      | Yes                                       |

**Notes**

[www] 03-18-2025 01-43-35