

Project Name

Location

Prepared By



NUVO 62-1720-EM

9" RD BLINK PRO EM BATT BACKUP

Notes

[www] 09-07-2025 11:00:04

General

| | |
|-----------------|-----------------------------------|
| Status | Active |
| Voltage | 120V |
| Finish | White |
| Safety Listing | cULus - Certified; cULus - Listed |
| Location Rating | Dry |
| Each UPC | 045923561269 |

Physical

| | |
|---------------|-------------|
| Diameter | 9.07 |
| Finish Family | White |
| Material | 5VA Plastic |

Additional Information

| | |
|------------------------|---|
| Additional Information | 90 Minute Battery Runtime; 24 Hour Recharge Time; Fixture not included; Battery should be changed approximately every 2 years |
| Installation Notes | Compatible with 3 in. and 4 in. J-Box & Pancake; 10.5ft Max Mounting Height |
| For Use With | 62-1720 |
| Warranty | 1-Year |

Compliance

| | |
|----------------------------|---|
| California Prop 65 | Lead |
| UL Application | Low Frequency Emergency Lighting Inverter |
| RoHS Compliant | Yes |
| FCC Compliant | Yes |
| Canadian Standard ICES-005 | Class A |