

Project Name

Location

Prepared By



# NUVO 62-1724-EM

9" SQ BLINK PRO EM BATT BACKUP

## Notes

[www] 08-08-2023 00:07:22

## General

Status	Active
Voltage	120V
Finish	White
Safety Listing	cULus - Certified; cULus - Listed
Location Rating	Dry
Each UPC	045923561306

## Physical

Finish Family	White
Material	5VA Plastic

## Additional Information

Additional Information	90 Minute Battery Runtime; 24 Hour Recharge Time; Fixture not included; Battery should be changed approximately every 2 years
Installation Notes	Compatible with 3 in. and 4 in. J-Box & Pancake; 10.5ft Max Mounting Height
For Use With	62-1724
Warranty	1-Year

## Compliance

California Prop 65	Lead
UL Application	Low Frequency Emergency Lighting Inverter
RoHS Compliant	Yes
FCC Compliant	Yes
Canadian Standard ICES-005	Class A