

Project Name

Location

Prepared By



## NUVO 62-1727-EM

9" SQ BLINK PRO EM BATT BACKUP

### Notes

[www] 10-27-2025 05:30:06

### General

Status	Active
Voltage	120V
Finish	Brushed Nickel
Safety Listing	cULus - Certified; cULus - Listed
Location Rating	Dry
Each UPC	045923561337

### Physical

Finish Family	Nickel
Material	Die-Cast Aluminum

### Additional Information

Additional Information	90 Minute Battery Runtime; 24 Hour Recharge Time; Fixture not included; Battery should be changed approximately every 2 years
Installation Notes	Compatible with 3 in. and 4 in. J-Box & Pancake; 10.5ft Max Mounting Height
For Use With	62-1727
Warranty	1-Year

### Compliance

California Prop 65	Lead
UL Application	Low Frequency Emergency Lighting Inverter
RoHS Compliant	Yes
FCC Compliant	Yes
Canadian Standard ICES-005	Class A